

Safe Drinking Water and Sanitary Condition Certificate

No. Hygienic/2025/45

Dated: 06/07/26

It is certified that inspection team headed by Dr. Rohit Nain M.O. (PNC) Karora (Name of officer with designation)

from Health Department Distt, Kaithal (Name of Department/ Officer)

Inspected the Shree Sai Public School (Name of School)

has safe drinking water facilities for the students and members of staff

of the institutions and in maintaining the Hygienic Sanitation Govt.

condition in the school building & the campus as per the norms prescribed

by the Central/ State/U.T. Govt.

Push to C.S. Ktl for N/A Bz

The above valid for a period of One Year.

Signature with seal

Senior Medical Officer
CHC Rajound (KTL)

Name

Designation

Name & Address of the officer/ Department:

*Refer to
MMS Co-
PNC Karora*

To.

Principal
Shree Sai Public
School, Karora

Dr. Rohit Nain
Dr. Rohit Nain
Medical Officer
CHC Rajound (KTL)
Regn. No. - IN-23039

06.7.26
Dr. Civil Surgeon
For Civil Surgeon
KAITHAL

Principal
PRINCIPAL
SHREE SAI PUBLIC SCHOOL
KARORA (KAITHAL)

Memo No:- 3593

Date:- 19/06/2026

Certificate No.
NABL0626HR18248

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : KNL/03993/6/2026 / Private	Sample Details	Date & Time
Sender : Principal Shree Sai Public School	Collected By	Staff
Location : , School Campus, Karora, Kalthal	Collection Date	18/06/2026 at 16:18
Sample Description : Drinking Water	Received at lab	18/06/2026 at 16:20
Latitude / Longitude : 76.991021 / 29.696672	Analysis Start Date	18/06/2026
	Analysis End Date	19/06/2026
	Sample Quantity	1000ML

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	<1	1 NTU	5 NTU	IS 3025 (Part-10):1984 (RA 2022)
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) :1984 (RA 2022)
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) :1984 (RA 2018)
4	Color	<5	5 Hazen Units	15 Hazen Units	IS 3025 (Part 4): 2021
5	Total Dissolved Solids @ 180°C ± 2°C	150	500 mg/lit.	2000 mg/lit.	IS 3025 (Part-16) : 2023
6	Total Hardness as CaCO ₃	100	200 mg/lit.	600 mg/lit.	IS 3025 (Part-21) : 2009 (RA 2023)
7	Calcium as Ca	20	75 mg/lit.	200 mg/lit.	IS 3025 (Part-40) :1991 (RA 2023)
8	Magnesium as Mg	24	30 mg/lit.	100 mg/lit.	IS 3025 (Part-46) (RA 2023)
9	Total Alkalinity	110	200 mg/lit.	600 mg/lit.	IS 3025 (Part-23) : 1986 (RA 2019)
10	Chloride as Cl	36	250 mg/lit.	1000 mg/lit.	IS 3025 (Part-32) :1988 (RA 2019)
11	Sulphate as SO ₄	10	200 mg/lit.	400 mg/lit.	USEPA-8051:2017
12	Fluoride as F	0.210	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition-4500F C
13	Iron as Fe	0.02	1.0 mg/lit.	1.0 mg/lit.	USEPA-8008:2017
14	Nitrate as NO ₃	1.0	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO ₃ D
15	pH @ 25°C	7.25	6.5 - 8.5	6.5 - 8.5	IS 3025 (Part-11) : 2022

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED KARNAL Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.



Sample analyzed by: *Tyjnind 28/6/26*

Am. Singh
AMIT KUMAR, CHIEF CHEMIST 19/06/26
STATE WATER TESTING LABORATORY, KARNAL
email:-chiefchemist.hr@phedharyana.gov.in

Principal
PRINCIPAL
SHREE SAI PUBLIC SCHOOL
KARORA (KALTHAL)